

# **Clayton County Environmental Health Tourist Accommodations Program**

## **Clayton County Board of Health Tourist Court Regulations**

### **Section -.07 Sewers. Amended.**

- (1) Sewers shall be designed in accordance with recognized engineering practices for the estimated sewage flow and shall be laid with watertight joints to a grade that will ensure a self-cleaning velocity. Sewers shall be constructed of durable materials properly vented and shall be installed at sufficient depth to withstand anticipated loads or other equally suitable means for protection of the pipe shall be used.
- (2) Each independent trailer space shall be provided with a sewer connection not less than three inches in diameter. Suitable fittings shall be provided at each sewer connection to permit a watertight junction to be made with the trailer outlet. Each sewer connection shall be so constructed that it can be closed and when not in use shall be capped to prevent escape of odors.